

H20 Rigid Sheet Cladding

Type(s) of cladding system
150 CELLULAR PVC BOARD CLADDING

MATERIAL

Material: [Cellular PVC \(PVC-ue\)](#)

Material Specification: [To BS 7619 1993:Type1, BBA Certified](#)

Colour stability Delta PI<15 in ACT test Delta L* less than -2 after 500 hrs in Suntest

Manufacturer: [Swish Building Products, Tamworth, Staffordshire, B79 7TF](#)

Manufacturer accreditation: [ISO9001/2](#)

PROFILES

Plank: [C001 100mm Shiplap, horizontal format](#)

Finish/Colour: [White](#)

Class 1Y Surface spread of flame to BS476 : Part 7 : 1987

ACCESSORIES

Starter: [Wall starter C028](#)

Top: [Two-part universal trim C290/291](#)

Vertical: [Two-part universal trim C290/291](#)
[Two-part corner trim C292/293](#)

Other: [N/A](#)

SUPPORTS

Description: [Treated timber battens & counterbattens](#)

Dimensions : [25mm x 38mm](#)

Placement: [At the base and head, across intermediate areas, at reveals, openings and changes of direction.](#)

Centres: [Maximum 600mm for all perimeter and intermediate battens.](#)

CLADDING FASTENINGS

Fixings: [Swish 33mm A4 Stainless steel nails \(C204\)](#)

Fixing location: [Secret fixing via groove in C001](#)

Fixing centres: [600mm centres maximum](#)

Running joints : [Butt joints, using C042 joint covers over support timber](#)

VENTILATION

Description: [25mm clear ventilated cavity](#)

Ventilation profiles : [Swish angle ventilator C065](#)

Breather membrane: [To BS 4016 : 1972](#)

Sealing: [C077 Swish low modulus silicone](#)

Insulation type: [N/A](#)

Special features : [Vent top of cladding through eaves box](#)

Fixing procedures as per [Swish Cladding Design & Specification Guide](#).

Please quote Swish References in all cases.